

Hollyrood Elementary School

Portland SD 1J

Mult_sch82A

Building Type		County	
School		Multnomah	
Street			
3560 Ne Hollyrood Ct			
City	State	Zip	
Portland	OR	97212	
Latitude	Longitude		
45.5412	122.627		
Tracking Code	Inspection Date		
Structural Engineering Report	9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Hollyrood Elementary School

Final RVS Score

Final Type

Final Score

W2

0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
215		1958	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
15701	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions