

Hosford Middle School

Mult_sch83A

Portland SD 1J

Building Type		County	
School		Multnomah	
Street			
2303 Se 28th Pl			
City		State	Zip
Portland		OR	97214
Latitude		Longitude	
45.50615		122.63713	
Tracking Code		Inspection Date	
Already Retrofitted		9/15/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Hosford Middle School

Final RVS Score

Final Type

Final Score

C2

-0.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
447		1925	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
77050	3	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions