

# Irvington Elementary School

Portland SD 1J

Mult\_sch85A

Building Type	County		
School	Multnomah		
Street			
1320 Ne Brazee St			
City	State	Zip	
Portland	OR	97212	
Latitude	Longitude		
45.54013	122.65194		
Tracking Code	Inspection Date		
Already Retrofitted	9/15/2006		



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Irvington Elementary School

## Final RVS Score

Final Type

Final Score

C2

-0.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
445		1932	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
65285	2	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions