

Maplewood Elementary School

Portland SD 1J

Mult_sch95A

Building Type		County	
School		Multnomah	
Street			
7452 Sw 52nd Ave			
City	State	Zip	
Portland	OR	97219	
Latitude	Longitude		
45.47091	122.72982		
Tracking Code	Inspection Date		
Already Retrofitted	9/15/2006		



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	0	0	1.3
Secondary										
Tertiary										0

Maplewood Elementary School

Final RVS Score

Final Type

Final Score

W2

1.3

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
315		1948	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
37191	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions