

# Marysville Elementary School

Portland SD 1J

Mult\_sch96A

Building Type		County	
School		Multnomah	
Street			
7733 Se Raymond St			
City	State	Zip	
Portland	OR	97206	
Latitude	Longitude		
45.48699	122.58349		
Tracking Code	Inspection Date		
Already Retrofitted	9/15/2006		



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	-0.4	0	0	-0.1
Secondary										
Tertiary										0

Marysville Elementary School

## Final RVS Score

Final Type

Final Score

W2

-0.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
336		1921	
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
53490	1	No	No

Plan Irregularities	Vertical Irregularities

Falling Hazards	Poor Conditions