

# Mt Tabor Middle School

Portland SD 1J

Mult\_sch97A

Building Type School	County Multnomah	
Street 5800 Se Ash St		
City Portland	State OR	Zip 97215
Latitude 45.52097	Longitude 122.60396	
Tracking Code Already Retrofitted	Inspection Date 9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Secondary										
Tertiary										0

Mt Tabor Middle School

## Final RVS Score

Final Type	Final Score
W2	0.9

## FEMA-154 Collapse Potential

Moderate (>1%)

# Mt Tabor Middle School

Mult\_sch97A

Enrollment 676	Year Built (Field Verified) 1952	Year Built (Alt. Source) 1952	Est. Decade Built
Total Area (square ft) 85800	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	