

Building Type Community_College	County Polk	
Street 915 SE Ash		
City Dallas	State OR	Zip 97338
Latitude 44.91664	Longitude 123.30372	
Tracking Code Miller 2004-05	Inspection Date 6/29/2004	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Branch - Dallas Academy (#107)

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Branch - Dallas Academy (#107)

Polk_coc01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1989	1989	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
21651	3	No	No
Plan Irregularities		Vertical Irregularities	
Yes: Unknown		Yes: Unknown	
Falling Hazards		Poor Conditions	
None			
None			
None			
			
S	General Site	S	General Site
			
S	General Site		