

Polk County Fire Dist 1

Polk County Fire Dist #1

Polk_fir01A

Building Type Fire - RFPD	County Polk	
Street 1800 Monmouth St		
City Independence	State OR	Zip 97351
Latitude 44.8518	Longitude 123.21608	
Tracking Code RVS in 2006	Inspection Date 7/10/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.2	0	-0.5	0	0	0	-0.6	0	2.1
Secondary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Tertiary		0	0	0	0	0	0	0	0	0

Polk County Fire Dist 1

Final RVS Score

Final Type	Final Score
RM1	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Polk County Fire Dist 1

Polk_fir01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Out of Plane Lateral-Force-Resistance Elements		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SE Plan Irregularity Primary		NE Vertical Irregularity Primary out-of-plane LFR elements	
		NE Vertical Irregularity Primary	
		NW Plan Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries