

Salem Fire Dept - Station 05

City of Salem

Polk_fir04A

Building Type Fire - City	County Polk	
Street 1520 NW Glen Creek Rd.		
City Salem	State OR	Zip 97304
Latitude 44.94994	Longitude 123.06519	
Tracking Code To be Re-built	Inspection Date 7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	0	-0.5	0	0	0	0	0	3.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Salem Fire Dept - Station 05

Final RVS Score

Final Type	Final Score
W1	3.9

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Salem Fire Dept - Station 05

Polk_fir04A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
9705	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W	General Site	NW	General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries