

# Polk County Sheriff

Polk County

Polk\_pol01A

Building Type Police - County	County Polk	
Street 850 Main St		
City Dallas	State OR	Zip 97338
Latitude 44.92084	Longitude 123.31567	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S4	2.8	0	-0.5	0	0	-0.4	0	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Polk County Sheriff

## Final RVS Score

Final Type	Final Score
S4	1.9

## FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1965	1965	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
86684	3	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners:Other (Adjacent Build/Entity)		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Heavy Cladding (thick stone or concrete)		None	
None		None	
None		None	
			
W Other	S General Site	E Field Verified Year Built	
Connection between new building (right) and old URM (left)	Attached sky bridge to county jail.	office building that contains sheriff's office was built 1965	

