

LaCreole Middle School

Dallas SD 2

Polk_sch01A

Building Type School	County Polk	
Street 701 SE La Creole Dr		
City Dallas	State OR	Zip 97338
Latitude 44.9232	Longitude 123.30103	
Tracking Code RVS in 2006	Inspection Date 7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary	W2	3.8	-2	-0.5	0	0	-0.4	0	0	0.9
Tertiary	PC1	2.6	0	-0.5	0	0	-0.4	0	0	1.7

LaCreole Middle School

Final RVS Score

Final Type	Final Score
C2	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

LaCreole Middle School

Polk_sch01A

Enrollment 768	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built 1960
Total Area (square ft) 115282	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Very Irregular Changes	
Reentrant Corners: Other (Adjacent Build/Entity)		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E General Site		E Vertical Irregularity Primary	
		S Plan Irregularity Secondary tilt-up gym connected to rm1 expansion	
			
E General Site plan irregularity - reentrant corners			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

LaCreole Middle School

Dallas SD 2

Polk_sch01B

Building Type	County	
School	Polk	
Street		
701 SE La Creole Dr		
City	State	Zip
Dallas	OR	97338
Latitude	Longitude	
44.92253	123.30098	
Tracking Code	Inspection Date	
RVS in 2006	7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	-0.4	0	0	0.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

LaCreole Middle School

Final RVS Score

Final Type	Final Score
RM1	0.9

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

LaCreole Middle School

Polk_sch01B

Enrollment 768	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built 1990
Total Area (square ft) 115282	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SW Primary Structural Type			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

LaCreole Middle School

Dallas SD 2

Polk_sch01C

Building Type	County	
School	Polk	
Street		
701 SE La Creole Dr		
City	State	Zip
Dallas	OR	97338
Latitude	Longitude	
44.92352	123.30141	
Tracking Code	Inspection Date	
RVS in 2006	7/20/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	-0.4	0	0	3.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

LaCreole Middle School

Final RVS Score

Final Type	Final Score
W2	3.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

LaCreole Middle School

Polk_sch01C

Enrollment 768	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built 1990
Total Area (square ft) 115282	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
S Other transition between old and new		NE Plan Irregularity Primary	
		E Vertical Irregularity Primary the new portion has popup light scoops.	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries