

Building Type	County	
School	Polk	
Street		
510 S 16th St		
City	State	Zip
Independence	OR	97351
Latitude	Longitude	
44.85497	123.21097	
Tracking Code	Inspection Date	
SER & RVS2006	7/10/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Talmadge Middle School

Final RVS Score

Final Type	Final Score
PC1	1.5

FEMA-154 Collapse Potential

Moderate (>1%)

No
Planview
Available



Talmadge Middle School

Polk_sch05A

Enrollment 404	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built 1960
Total Area (square ft) 84090	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Out of Plane Lateral-Force-Resistance Elements		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
Other: Light Cladding		None	
			
W Plan Irregularity Primary		SW Plan Irregularity Primary	
		W Plan Irregularity Secondary	
			
E Plan Irregularity Primary		E Primary Structural Type	
		SW Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Building Type	County	
School	Polk	
Street		
510 S 16th St		
City	State	Zip
Independence	OR	97351
Latitude	Longitude	
44.85558	123.21049	
Tracking Code	Inspection Date	
SER & RVS2006	7/10/2006	



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	PC1	2.6	0	-0.5	0	0	0	-0.6	0	1.5
Tertiary		0	0	0	0	0	0	0	0	0

Talmadge Middle School

Final RVS Score

Final Type	Final Score
C2	0.7

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Talmadge Middle School

Polk_sch05B

Enrollment 404	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built 1960
Total Area (square ft) 84090	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Out of Plane Lateral-Force-Resistance Elements		Steps in Elevation View: Single Change	
Reentrant Corners: Other		None	
None		None	
Falling Hazards		Poor Conditions	
Other: Smokestack		None	
Other: Light Cladding		None	
None		None	
			
NE General Site	NE Plan Irregularity Secondary	NW Plan Irregularity Secondary	
			
NW Falling Hazard			