

# Central High School

Polk\_sch06A

Central SD 13J

Building Type		County	
School		Polk	
Street			
1530 Monmouth St			
City		State	Zip
Independence		OR	97351
Latitude		Longitude	
44.85203		123.20995	
Tracking Code		Inspection Date	
SER & RVS2006		7/27/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	S3	3.2	0	-0.5	0	0	0	-0.6	0	2.1
Tertiary		0	0	0	0	0	0	0	0	0

Central High School

## Final RVS Score

Final Type

Final Score

C2

0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Central High School

Polk\_sch06A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
858	1983	1950	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
138700	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
Large Diaphragm or Central Opening	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW Plan Irregularity Secondary



NE Plan Irregularity Primary



SE Plan Irregularity Primary  
Also shows a vertical irregularity.



E Other  
building date



N Vertical Irregularity Primary  
Also shows an out of plane lateral system.



N Vertical Irregularity Secondary  
Also shows a plan irregularity due to an adjacent building.  
Building B is on the left and building A is on the right.



N General Site

# Central High School

Central SD 13J

Polk\_sch06B

Building Type		County	
School		Polk	
Street			
1530 Monmouth St			
City	State	Zip	
Independence	OR	97351	
Latitude		Longitude	
44.85182		123.20974	
Tracking Code		Inspection Date	
SER & RVS2006		7/27/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Central High School

## Final RVS Score

Final Type

Final Score

C2

0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
858	1950	1950	1950
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
138700	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Very Irregular Changes
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: Single Change (Adjacent Building/Entity)
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SW Plan Irregularity Primary



SE Plan Irregularity Secondary

NW Vertical Irregularity Secondary  
Building B is on the left and building A is on the right.

# Central High School

Polk\_sch06C

Central SD 13J

Building Type		County	
School		Polk	
Street			
1530 Monmouth St			
City		State	Zip
Independence		OR	97351
Latitude		Longitude	
44.85266		123.20959	
Tracking Code		Inspection Date	
SER & RVS2006		7/27/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	0	0	0	-0.6	0	0.7
Secondary	S3	3.2	0	-0.5	0	0	0	-0.6	0	2.1
Tertiary		0	0	0	0	0	0	0	0	0

Central High School

## Final RVS Score

Final Type

Final Score

RM1

0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
858		1950	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
138700	2	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Building On Hill or Sloped Site
Non-Parallel System	Steps in Elevation View: 2 to 3 Changes
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NW Vertical Irregularity Secondary



NW Vertical Irregularity Secondary



S General Site

