

Building Type	County	
School	Polk	
Street		
150 S 4th St		
City	State	Zip
Independence	OR	97351
Latitude	Longitude	
44.85257	123.18951	
Tracking Code	Inspection Date	
Structural Engineering Report	9/15/2006	



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	-1	-0.5	-0.2	0	0	-0.6	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Independence Elementary School

## Final RVS Score

Final Type	Final Score
URM	-0.5

## FEMA-154 Collapse Potential

Very High (100%)

No  
Planview  
Available



# Independence Elementary School

Polk\_sch09A

Enrollment 308	Year Built (Field Verified) 1925	Year Built (Alt. Source) 1925	Est. Decade Built
Total Area (square ft) 40450	Number of Stories 2	Basement No	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	