

Building Type	County	
School	Polk	
Street		
2623 Doaks Ferry Rd Nw		
City	State	Zip
Salem	OR	97304
Latitude	Longitude	
44.9724	123.07732	
Tracking Code	Inspection Date	
Structural Engineering Report		9/15/2006



Seismicity Zone: High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	-0.8	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Brush College Elementary School

Final RVS Score

Final Type	Final Score
W2	-0.5

FEMA-154 Collapse Potential

Very High (100%)

No
Planview
Available



OregonGeology

Brush College Elementary School

Polk_sch13A

Enrollment 372	Year Built (Field Verified) 1860	Year Built (Alt. Source) 1860	Est. Decade Built
Total Area (square ft) 51780	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries