

Building Type	County	
School	Polk	
Street		
1500 Doaks Ferry Rd Nw		
City	State	Zip
Salem	OR	97304
Latitude	Longitude	
44.95562	123.07654	
Tracking Code	Inspection Date	
Structural Engineering Report		
9/15/2006		



Seismicity Zone: High										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	0	0	3.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Chapman Hill Elementary School

Final RVS Score

Final Type	Final Score
W2	3.7

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available

Chapman Hill Elementary School

Polk_sch16A

Enrollment 494	Year Built (Field Verified) 1985	Year Built (Alt. Source) 1985	Est. Decade Built
Total Area (square ft) 59528	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Falling Hazards		Poor Conditions	