

South Sherman Elementary School

Sherman County SD

Sher_sch01A

Building Type School	County Sherman	
Street 212 Ne North St		
City Grass Valley	State OR	Zip 97029
Latitude 45.36237	Longitude 120.78127	
Tracking Code RVS in 2006	Inspection Date 8/28/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	W2	4.8	-3	-0.5	0	1.6	-0.8	0	0	2.1
Tertiary		0	0	0	0	0	0	0	0	0

South Sherman Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



South Sherman Elementary School

Sher_sch01A

Enrollment 53	Year Built (Field Verified) 1992	Year Built (Alt. Source) 1992	Est. Decade Built 1990
Total Area (square ft) 31900	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
 N Elevation View		 N Primary Structural Type	
 NE Vertical Irregularity Primary		 SE Plan Irregularity Primary	
 S Elevation View		 W Elevation View	
 NW Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries