

# North Sherman Elementary School

Sherman County SD

Sher\_sch03A

Building Type School	County Sherman	
Street 1 Barnett St		
City Wasco	State OR	Zip 97065
Latitude 45.59294	Longitude 120.69572	
Tracking Code RVS in 2006	Inspection Date 8/28/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	-0.5	-0.4	0	0	0	0	2.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

North Sherman Elementary School

## Final RVS Score

Final Type	Final Score
C2	2.7

## FEMA-154 Collapse Potential

Low (<1%)



# North Sherman Elementary School

Sher\_sch03A

Enrollment 72	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built 1910
Total Area (square ft) 32180	Number of Stories 2	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards Unreinforced Chimneys Parapets: General Other: Ornamental Hazard Over Exit		Poor Conditions None None None	
			
S	Falling Hazard	SE	Pounding Potential
			
NE	Falling Hazard	NE	Plan Irregularity Primary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# North Sherman Elementary School

Sherman County SD

Sher\_sch03B

Building Type	County
School	Sherman
Street	
1 Barnett St	
City	State Zip
Wasco	OR 97065
Latitude	Longitude
45.59288	120.69507
Tracking Code	Inspection Date
RVS in 2006	8/28/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	0	0	1.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

North Sherman Elementary School

## Final RVS Score

Final Type	Final Score
W2	1.3

## FEMA-154 Collapse Potential

Moderate (>1%)



# North Sherman Elementary School

Sher\_sch03B

Enrollment 72	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built 1950
Total Area (square ft) 32180	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions Visible Dry Rot None None	
			
NE Vertical Irregularity Primary	NW Pounding Potential	SW Plan Irregularity Primary	
			
SW Elevation View	S Poor Condition		



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries