

Nehalem VFD/City Hall

City of Nehalem

Till_fir07A

Building Type	County
Fire - City	Tillamook
Street	
35900 8th St	
City	State Zip
Nehalem	OR 97131
Latitude	Longitude
45.71719	123.89543
Tracking Code	Inspection Date
RVS in 2006	9/6/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	2.8	-1	-0.5	-1	0	-0.4	0	0	-0.1
Secondary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Tertiary		0	0	0	0	0	0	0	0	0

Nehalem VFD/City Hall

Final RVS Score

Final Type	Final Score
RM1	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Nehalem VFD/City Hall

Till_fir07A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1900	1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change	
None		Soft Story	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E Building Name		E Plan Irregularity Primary	
		NE Elevation View	
		SW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries