

Nestucca RFPD

Building Type Fire - RFPD	County Tillamook	
Street 48000 Hwy 101 S		
City Neskowin	State OR	Zip 97149
Latitude 45.10733	Longitude 123.97748	
Tracking Code RVS in 2006	Inspection Date 9/7/2006	



Seismicity Zone: Very High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	4.4	-2.5	-0.5	0	0	0	0	0	1.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Nestucca RFPD Neskowin #84

## Final RVS Score

Final Type	Final Score
W1	1.4

## FEMA-154 Collapse Potential

Moderate (&gt;1%)

No  
Planview  
Available



OregonGeology

# Nestucca RFPD Neskowin #84

Till\_fir13A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Torsion: Eccentric Stiffness		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S	Plan Irregularity Primary	SE	Elevation View
			
N	Plan Irregularity Secondary	W	Elevation View



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries