

Building Type	County	
Fire - RFPD	Tillamook	
Street		
32750 Upper Nestucca River Road		
City	State	Zip
Blaine	OR	97108
Latitude	Longitude	
45.26291	123.69345	
Tracking Code	Inspection Date	
RVS in 2006	9/7/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	2.4	0	-0.8	0	2.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Nestucca RFPD Blaine #86

Final RVS Score

Final Type

Final Score

W2

2.9

FEMA-154 Collapse Potential

Low (<1%)

No Planview Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Single Change
Torsion: Eccentric Stiffness	None
None	None


Falling Hazards	Poor Conditions
None	None
None	None
None	None



W Building Name



S Elevation View

S Primary Structural Type
WOOD RAFTERS

NW Elevation View



NW Plan Irregularity Primary



NW Plan Irregularity Primary

