

Nestucca High School

Nestucca Valley SD 101J

Till_sch08A

Building Type School	County Tillamook	
Street 34660 Parkway Dr		
City Cloverdale	State OR	Zip 97112
Latitude 45.20406	Longitude 123.88866	
Tracking Code SER & RVS2006	Inspection Date 9/7/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	2.8	-1	0	-1	0	-0.4	0	0	0.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Nestucca High School

Final RVS Score

Final Type	Final Score
C2	0.4

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Nestucca High School

Till_sch08A

Enrollment 213	Year Built (Field Verified) 1929	Year Built (Alt. Source) 1961	Est. Decade Built 1920
Total Area (square ft) 21252	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Vertical Irregularity Primary OLD AUDITORIUM GONE			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Nestucca High School

Nestucca Valley SD 101J

Till_sch08B

Building Type School	County Tillamook	
Street 34660 Parkway Dr		
City Cloverdale	State OR	Zip 97112
Latitude 45.20367	Longitude 123.8891	
Tracking Code SER & RVS2006	Inspection Date 9/7/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	-0.4	0	0	3.4
Secondary	C2	2.8	0	0	0	0	-0.4	0	0	2.4
Tertiary		0	0	0	0	0	0	0	0	0

Nestucca High School

Final RVS Score

Final Type	Final Score
C2	2.4

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Nestucca High School

Till_sch08B

Enrollment 213	Year Built (Field Verified) 1968	Year Built (Alt. Source) 1961	Est. Decade Built 1960
Total Area (square ft) 21252	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards Other: Ornamental Hazard Over Exit		Poor Conditions None None None	
 NE Falling Hazard		 NW Elevation View	
 W Primary Structural Type C2 WALLS		 E General Site B IS GREY MANSARD AND YOU CAN SEE NO ATTACHMENT TO STADIUM	

Nestucca High School

Nestucca Valley SD 101J

Till_sch08C

Building Type School	County Tillamook	
Street 34660 Parkway Dr		
City Cloverdale	State OR	Zip 97112
Latitude 45.20429	Longitude 123.88766	
Tracking Code SER & RVS2006	Inspection Date 9/7/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	-0.4	0	0	3.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Nestucca High School

Final RVS Score

Final Type	Final Score
W2	3.4

FEMA-154 Collapse Potential

Low (<1%)



0 150 300
feet



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Nestucca High School

Till_sch08C

Enrollment 213	Year Built (Field Verified) 1961	Year Built (Alt. Source) 1961	Est. Decade Built 1960
Total Area (square ft) 21252	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions Visible Dry Rot None None	
 W Elevation View		 NW Elevation View	