

Nestucca Valley Middle School

Nestucca Valley SD 101J

Till_sch09A

Building Type	County
School	Tillamook
Street	
19995 Blaine Rd	
City	State Zip
Beaver	OR 97108
Latitude	Longitude
45.27643	123.82506
Tracking Code	Inspection Date
SER & RVS2006	9/7/2006



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	-1	0	0	-0.8	0	-0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Nestucca Valley Middle School

Final RVS Score

Final Type	Final Score
W2	-0.5

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Nestucca Valley Middle School

Till_sch09A

Enrollment 220	Year Built (Field Verified) 1936	Year Built (Alt. Source) 1936	Est. Decade Built 1930
Total Area (square ft) 71584	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions None None None	
			
N Vertical Irregularity Primary		N Elevation View	
		W Plan Irregularity Primary	
			
W Elevation View		SW Building Quality LIBRARY IMPROVEMENT THIS CORNER PER BOND MEASURE	
		S Vertical Irregularity Primary	
			
SE Elevation View OLDEST PART OF SCHOOL		NE Falling Hazard	
		NE Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Nestucca Valley Middle School

Nestucca Valley SD 101J

Till_sch09B

Building Type	County	
School	Tillamook	
Street		
19995 Blaine Rd		
City	State	Zip
Beaver	OR	97108
Latitude	Longitude	
45.27638	123.82442	
Tracking Code	Inspection Date	
SER & RVS2006	9/7/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	0	0	0	0	-0.8	0	1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Nestucca Valley Middle School

Final RVS Score

Final Type	Final Score
W2	1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Nestucca Valley Middle School

Till_sch09B

Enrollment 220	Year Built (Field Verified) 1936	Year Built (Alt. Source) 1936	Est. Decade Built 1960
Total Area (square ft) 71584	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions None None None	
 SE Elevation View		 NE Vertical Irregularity Primary	
 N Falling Hazard		 NW Plan Irregularity Primary	