

East Elementary School

Till_sch10A

Tillamook SD 9

Building Type	County	
School	Tillamook	
Street		
3905 Alder Ln		
City	State	Zip
Tillamook	OR	97141
Latitude	Longitude	
45.45379	123.81988	
Tracking Code	Inspection Date	
SER & RVS2006	9/8/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	-0.5	0	0	0	-0.8	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

East Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

East Elementary School

Till_sch10A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built		
461	1953	1953	1950		
Total Area (square ft)	Number of Stories	Basement	Pounding Potential		
51796	1	No	Yes		
Plan Irregularities		Vertical Irregularities			
Reentrant Corners: T shaped		Steps in Elevation View: 2 to 3 Changes			
None		None			
None		None			
Falling Hazards		Poor Conditions			
Other: Brick Veneer		None			
None		None			
None		None			
	N Elevation View		N Falling Hazard		N Field Verified Year Built
	NW Elevation View		N Pounding Potential		SE Plan Irregularity Primary
	S Pounding Potential		SE Plan Irregularity Primary		S General Site



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

East Elementary School

Till_sch10A



S Elevation View



S Elevation View



SW Elevation View



SW Elevation View
CONN TO MODULAR



NW General Site



NW Elevation View

East Elementary School

Tillamook SD 9

Till_sch10B

Building Type School	County Tillamook	
Street 3905 Alder Ln		
City Tillamook	State OR	Zip 97141
Latitude 45.45383	Longitude 123.81877	
Tracking Code SER & RVS2006	Inspection Date 9/8/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	-2	0	0	0	0	-0.8	0	1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

East Elementary School

Final RVS Score

Final Type	Final Score
W2	1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

East Elementary School

Till_sch10B

Enrollment 461	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built 1950
Total Area (square ft) 51796	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change None None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions None None None	
			
NE Elevation View		SW Vertical Irregularity Primary	

East Elementary School

Tillamook SD 9

Till_sch10C

Building Type School	County Tillamook	
Street 3905 Alder Ln		
City Tillamook	State OR	Zip 97141
Latitude 45.45354	Longitude 123.82079	
Tracking Code SER & RVS2006	Inspection Date 9/8/2006	



Seismicity Zone: Very High

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	3.8	0	0	0	0	0	-0.8	0	3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

East Elementary School

Final RVS Score

Final Type	Final Score
W2	3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

East Elementary School

Till_sch10C

Enrollment 461	Year Built (Field Verified) 1953	Year Built (Alt. Source) 1953	Est. Decade Built 1950
Total Area (square ft) 51796	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Elevation View		NW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries