

McCrae Activity Center

Blue Mountain CC

Umat_coc03A

Building Type		County	
Community_College		Umatilla	
Street			
2411 NW Carden Ave			
City	State	Zip	
Pendleton	OR	97801	
Latitude		Longitude	
45.67737		118.81681	
Tracking Code		Inspection Date	
Miller 2004-05		3/1/2007	

Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary	PC1	3.2	0	-0.5	0	0	0	0	0	2.7
Tertiary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1

McCrae Activity Center

Final RVS Score

Final Type


Final Score

C2

1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1976	1976	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
50786	3	Yes	No

Plan Irregularities	Vertical Irregularities
Yes: Unknown	Yes: Unknown

Falling Hazards	Poor Conditions
None	
None	

