

Pilot Rock RFPD

Umat_fir12A

Pilot Rock RFPD

Building Type Fire - RFPD	County Umatilla	
Street Ne 4th & Ne Elm		
City Pilot Rock	State OR	Zip 97868
Latitude 45.48642	Longitude 118.82854	
Tracking Code RVS in 2006	Inspection Date 8/1/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	-0.5	0	0	-0.6	0	0	2.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Pilot Rock RFPD

Final RVS Score

Final Type	Final Score
S3	2.7

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Pilot Rock RFPD

Umat_fir12A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		1987	1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
3626	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries