

St. Anthony Hospital - Pendleton

Catholic Health Initiatives NFP

Umat_hos02A

Building Type		County	
Hospital		Umatilla	
Street			
1601 SE Court Ave			
City	State	Zip	
Pendleton	OR	97801	
Latitude		Longitude	
45.67374		118.76889	
Tracking Code		Inspection Date	
New Building		8/1/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	4	-2	-0.5	-0.4	0	0	0	0	1.1
Secondary	C2	4	-2	-0.5	-0.4	0	0	0	0	1.1
Tertiary	URM	3	-1.5	-0.5	-0.4	0	0	0	0	0.6

St. Anthony Hospital - Pendleton

Final RVS Score

Final Type

Final Score

URM

0.6

FEMA-154 Collapse Potential

Low (<1%)



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		2006	1940
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
200654	4	Yes	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other (Adjacent Build/Entity)	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
Reentrant Corners: T shaped	None
None	None

Falling Hazards	Poor Conditions
Other: Smokestack	None
Other: Smokestack	None
Other: Ornamental Hazard Over Exit	None




S General Site



E Falling Hazard



NW Plan Irregularity Secondary



NE Falling Hazard



NE Plan Irregularity Primary



St. Anthony Hospital - Pendleton

Catholic Health Initiatives NFP

Umat_hos02B

Building Type		County	
Hospital		Umatilla	
Street			
1601 SE Court Ave			
City	State	Zip	
Pendleton	OR	97801	
Latitude		Longitude	
45.67322		118.769	
Tracking Code		Inspection Date	
New Building		8/1/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	3.2	-2	-0.5	0	0	0	0	0	0.7
Secondary	C2	4	-2	-0.5	0	0	0	0	0	1.5
Tertiary		0	0	0	0	0	0	0	0	0

St. Anthony Hospital - Pendleton

Final RVS Score

Final Type

Final Score

C1

0.7

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		2006	1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
200654	4	Yes	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: Very Irregular Changes
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
None	Building On Hill or Sloped Site

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SE Elevation View



E Plan Irregularity Secondary



SW Vertical Irregularity Primary



St. Anthony Hospital - Pendleton

Catholic Health Initiatives NFP

Umat_hos02C

Building Type		County	
Hospital		Umatilla	
Street			
1601 SE Court Ave			
City	State	Zip	
Pendleton	OR	97801	
Latitude		Longitude	
45.6732		118.76995	
Tracking Code		Inspection Date	
New Building		8/1/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	3.2	-2	-0.5	0	0	0	0	0	0.7
Secondary	C2	4	-2	-0.5	0	1.6	0	0	0	3.1
Tertiary	S2	4	-2	-0.5	0	0	0	0	0	1.5

St. Anthony Hospital - Pendleton

Final RVS Score

Final Type

Final Score

C1

0.7

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries


Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
		2006	1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
200654	4	No	No

Plan Irregularities	Vertical Irregularities
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes
Reentrant Corners: Other	Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)
None	Building On Hill or Sloped Site

Falling Hazards	Poor Conditions
None	None
None	None
None	None



W Building Name



SW Elevation View