

Rocky Heights Elementary School

Hermiston SD 8

Umat_sch04A

Building Type	County	
School	Umatilla	
Street		
650 W Standard Ave		
City	State	Zip
Hermiston	OR	97838
Latitude	Longitude	
45.84472	119.2987	
Tracking Code	Inspection Date	
RVS in 2006	8/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	3.2	0	-0.5	0	0	0	-1	0	1.7
Secondary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Rocky Heights Elementary School

Final RVS Score

Final Type	Final Score
C2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



Rocky Heights Elementary School

Umat_sch04A

Enrollment 408	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1960
Total Area (square ft) 40062	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Steps in Elevation View: Single Change (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
 N Elevation View		 N Elevation View	
		 S Field Verified Year Built	

Rocky Heights Elementary School

Hermiston SD 8

Umat_sch04B

Building Type School	County Umatilla	
Street 650 W Standard Ave		
City Hermiston	State OR	Zip 97838
Latitude 45.84492	Longitude 119.29892	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	W2	4.8	-3	-0.5	0	1.6	0	-1.2	0	1.7
Tertiary		0	0	0	0	0	0	0	0	0

Rocky Heights Elementary School

Final RVS Score

Final Type	Final Score
RM1	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Rocky Heights Elementary School

Umat_sch04B

Enrollment 408	Year Built (Field Verified) 1962	Year Built (Alt. Source) 1962	Est. Decade Built 1980
Total Area (square ft) 40062	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	