

# West Park Elementary School

Hermiston SD 8

Umat\_sch06A

Building Type School	County Umatilla	
Street 555 Sw 7th St		
City Hermiston	State OR	Zip 97838
Latitude 45.83671	Longitude 119.30015	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

West Park Elementary School

### Final RVS Score

Final Type	Final Score
C2	-0.1

### FEMA-154 Collapse Potential

Very High (100%)




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# West Park Elementary School

Umat\_sch06A

Enrollment 406	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 49875	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W Building Name	S Elevation View	NE Elevation View	

# West Park Elementary School

Hermiston SD 8

Umat\_sch06B

Building Type School	County Umatilla	
Street 555 Sw 7th St		
City Hermiston	State OR	Zip 97838
Latitude 45.83729	Longitude 119.30028	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	0	0	0	0	-1.2	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

West Park Elementary School

## Final RVS Score

Final Type	Final Score
C2	2.4

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

# West Park Elementary School

Umat\_sch06B

Enrollment 406	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 49875	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 E Elevation View			

# West Park Elementary School

Hermiston SD 8

Umat\_sch06C

Building Type School	County Umatilla	
Street 555 Sw 7th St		
City Hermiston	State OR	Zip 97838
Latitude 45.83767	Longitude 119.3	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	0	0	0	0	-1.2	0	2.4
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

West Park Elementary School

## Final RVS Score

Final Type	Final Score
C2	2.4

## FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# West Park Elementary School

Umat\_sch06C

Enrollment 406	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 49875	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 SW Elevation View			

# West Park Elementary School

Hermiston SD 8

Umat\_sch06D

Building Type School	County Umatilla	
Street 555 Sw 7th St		
City Hermiston	State OR	Zip 97838
Latitude 45.8362	Longitude 119.30027	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Secondary	PC1	3.2	0	-0.5	0	0	0	-1	0	1.7
Tertiary		0	0	0	0	0	0	0	0	0

West Park Elementary School

### Final RVS Score

Final Type	Final Score
PC1	1.7

### FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# West Park Elementary School

Umat\_sch06D

Enrollment 406	Year Built (Field Verified) 1950	Year Built (Alt. Source) 1950	Est. Decade Built 1950
Total Area (square ft) 49875	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 W Elevation View			