

Washington Elementary School

Pendleton SD 16

Umat_sch11A

Building Type School	County Umatilla	
Street 1205 SE Byers Ave		
City Pendleton	State OR	Zip 97801
Latitude 45.67551	Longitude 118.77422	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Tertiary	C2	3.2	-2	-0.5	-1	0	-0.6	0	0	-0.9

Washington Elementary School

Final RVS Score

Final Type	Final Score
C2	-0.9

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Washington Elementary School

Umat_sch11A

Enrollment 411	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1958	Est. Decade Built 1940
Total Area (square ft) 34552	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
W Elevation View		NE Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Washington Elementary School

Pendleton SD 16

Umat_sch11B

Building Type School	County Umatilla	
Street 1205 SE Byers Ave		
City Pendleton	State OR	Zip 97801
Latitude 45.67603	Longitude 118.77438	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	0	-0.2	0	0	5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Washington Elementary School

Final RVS Score

Final Type	Final Score
W1	5

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Washington Elementary School

Umat_sch11B

Enrollment 411	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1958	Est. Decade Built 1960
Total Area (square ft) 34552	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	

Washington Elementary School

Pendleton SD 16

Umat_sch11C

Building Type School	County Umatilla	
Street 1205 SE Byers Ave		
City Pendleton	State OR	Zip 97801
Latitude 45.67571	Longitude 118.77357	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	1.6	-0.8	0	0	2.1
Secondary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Tertiary		0	0	0	0	0	0	0	0	0

Washington Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Washington Elementary School

Umat_sch11C

Enrollment 411	Year Built (Field Verified) 1958	Year Built (Alt. Source) 1958	Est. Decade Built 1980
Total Area (square ft) 34552	Number of Stories 1	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) Steps in Elevation View: 2 to 3 Changes None	
Falling Hazards None None None		Poor Conditions None None None	
			
NE Elevation View		S Elevation View	