

Grove Elementary School

Milton-Freewater Unified SD 7

Umat_sch16A

Building Type School	County Umatilla	
Street 129 Se 15th St		
City Milton-Freewater	State OR	Zip 97862
Latitude 45.92203	Longitude 118.37757	
Tracking Code RVS in 2006	Inspection Date 8/2/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	-0.4	0	0	0.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Grove Elementary School

Final RVS Score

Final Type	Final Score
URM	0.6

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Grove Elementary School

Umat_sch16A

Enrollment 370	Year Built (Field Verified) 1915	Year Built (Alt. Source) 1915	Est. Decade Built 1900
Total Area (square ft) 27737	Number of Stories 2	Basement	Pounding Potential Yes
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions Poor Masonry None None	
 W Poor Condition			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Grove Elementary School

Milton-Freewater Unified SD 7

Umat_sch16B

Building Type School	County Umatilla	
Street 129 Se 15th St		
City Milton-Freewater	State OR	Zip 97862
Latitude 45.92183	Longitude 118.37749	
Tracking Code RVS in 2006	Inspection Date 8/2/2006	



Seismicity Zone: Moderate										
FEMA 154 Rapid Visual Screening Score Card										
	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Grove Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Grove Elementary School

Umat_sch16B

Enrollment 370	Year Built (Field Verified) 1984	Year Built (Alt. Source) 1915	Est. Decade Built 1980
Total Area (square ft) 27737	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: Single Change	
Reentrant Corners: L Shaped		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S Elevation View		SE Plan Irregularity Primary	

Grove Elementary School

Milton-Freewater Unified SD 7

Umat_sch16C

Building Type School	County Umatilla	
Street 129 Se 15th St		
City Milton-Freewater	State OR	Zip 97862
Latitude 45.922	Longitude 118.37711	
Tracking Code RVS in 2006	Inspection Date 8/2/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Grove Elementary School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Grove Elementary School

Umat_sch16C

Enrollment 370	Year Built (Field Verified) 1915	Year Built (Alt. Source) 1915	Est. Decade Built 1960
Total Area (square ft) 27737	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity)		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other None		Steps in Elevation View: Single Change (Adjacent Building/Entity) None	
Falling Hazards None		Poor Conditions None	
None		None	
None		None	
 NE Elevation View		 N Vertical Irregularity Primary	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries