

McKay Creek Elementary School

Pendleton SD 16

Umat_sch24A

Building Type School	County Umatilla	
Street 1539 Sw 44th St		
City Pendleton	State OR	Zip 97801
Latitude 45.64604	Longitude 118.82535	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

McKay Creek Elementary School

Final RVS Score

Final Type	Final Score
W2	0.5

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

McKay Creek Elementary School

Umat_sch24A

Enrollment 360	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built 1960
Total Area (square ft) 35317	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) Reentrant Corners: L Shaped None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 N Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

McKay Creek Elementary School

Pendleton SD 16

Umat_sch24B

Building Type School	County Umatilla	
Street 1539 Sw 44th St		
City Pendleton	State OR	Zip 97801
Latitude 45.64596	Longitude 118.82606	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	1.6	-0.8	0	0	2.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

McKay Creek Elementary School

Final RVS Score

Final Type	Final Score
W2	2.1

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

McKay Creek Elementary School

Umat_sch24B

Enrollment 360	Year Built (Field Verified) 1966	Year Built (Alt. Source) 1966	Est. Decade Built 1980
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Steps in Elevation View: Single Change (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	
			
SW Elevation View		S Elevation View	
			
		SE Elevation View	