

Clara Brownell Middle School

Umatilla SD 6R

Umat_sch27A

Building Type School	County Umatilla	
Street 1460 7th St		
City Umatilla	State OR	Zip 97882
Latitude 45.91716	Longitude 119.338	
Tracking Code RVS in 2006	Inspection Date 8/15/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clara Brownell Middle School

Final RVS Score

Final Type	Final Score
C2	0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Clara Brownell Middle School

Umat_sch27A

Enrollment 298	Year Built (Field Verified) 1915	Year Built (Alt. Source) 1915	Est. Decade Built 1950
Total Area (square ft) 90515	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
Unreinforced Chimneys		None	
None		None	
None		None	
			
N Falling Hazard		NE Elevation View	
		SE Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Clara Brownell Middle School

Umatilla SD 6R

Umat_sch27B

Building Type	County
School	Umatilla
Street	
1460 7th St	
City	State Zip
Umatilla	OR 97882
Latitude	Longitude
45.91657	119.33819
Tracking Code	Inspection Date
RVS in 2006	8/15/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Clara Brownell Middle School

Final RVS Score

Final Type

Final Score

C2

0.3

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Clara Brownell Middle School

Umat_sch27B

Enrollment 298	Year Built (Field Verified) 1915	Year Built (Alt. Source) 1915	Est. Decade Built 1950
Total Area (square ft)	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity)		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Reentrant Corners: Other		None	
None		None	
Falling Hazards None		Poor Conditions None	
None		None	
None		None	
			
SW Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries