

# North Powder RFPD

North Powder RFPD

Unio\_fir05A

Building Type Fire - RFPD	County Union	
Street 919 E St		
City North Powder	State OR	Zip 97867
Latitude 45.0297	Longitude 117.92079	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	-0.5	0	0	0	-1.2	0	1.9
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0


North Powder RFPD

Final RVS Score

Final Type RM1	Final Score 1.9
-------------------	--------------------

FEMA-154 Collapse Potential

Moderate (>1%)
----------------



# North Powder RFPD

Unio\_fir05A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
W Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries