

# Willow Elementary School

La Grande SD 1

Unio\_sch01A

Building Type School	County Union	
Street 1305 Willow St		
City La Grande	State OR	Zip 97850
Latitude 45.32373	Longitude 118.07916	
Tracking Code RVS in 2006	Inspection Date 8/3/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	0	-0.8	0	0.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Willow Elementary School

### Final RVS Score

Final Type	Final Score
URM	0.2

### FEMA-154 Collapse Potential

High (>10%)



OregonGeology

# Willow Elementary School

Unio\_sch01A

Enrollment 155	Year Built (Field Verified) 1924	Year Built (Alt. Source) 1924	Est. Decade Built 1920
Total Area (square ft) 17919	Number of Stories 1	Basement	Pounding Potential No
<b>Plan Irregularities</b> Reentrant Corners:T shaped (Adjacent Build/Entity) Out of Plane Lateral-Force-Resistance Elements None		<b>Vertical Irregularities</b> Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) None None	
<b>Falling Hazards</b> Unreinforced Chimneys Parapets: Unreinforced Around Entire Building None		<b>Poor Conditions</b> Cracks Poor Masonry None	
 W Other separation between buildings		 W Building Name	
 W Primary Structural Type		 W Poor Condition	
		 W Falling Hazard	
		 E Falling Hazard	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
 Oregon Department of Geology and Mineral Industries

# Willow Elementary School

La Grande SD 1

Unio\_sch01B

Building Type School	County Union	
Street 1305 Willow St		
City La Grande	State OR	Zip 97850
Latitude 45.32404	Longitude 118.07914	
Tracking Code RVS in 2006	Inspection Date 8/3/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Willow Elementary School

### Final RVS Score

Final Type	Final Score
C2	-0.1

### FEMA-154 Collapse Potential


Very High (100%)



OregonGeology

# Willow Elementary School

Unio\_sch01B

Enrollment 155	Year Built (Field Verified) 1924	Year Built (Alt. Source) 1924	Est. Decade Built 1950
Total Area (square ft) 17919	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Steps in Elevation View: Single Change (Adjacent Building/Entity) None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions Poor Masonry None None	
 SE Poor Condition		 NE Elevation View	

# Willow Elementary School

La Grande SD 1

Unio\_sch01C

Building Type School	County Union	
Street 1305 Willow St		
City La Grande	State OR	Zip 97850
Latitude 45.32356	Longitude 118.07917	
Tracking Code RVS in 2006	Inspection Date 8/3/2006	



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Willow Elementary School

### Final RVS Score

Final Type	Final Score
C2	-0.1

### FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

# Willow Elementary School

Unio\_sch01C

Enrollment 155	Year Built (Field Verified) 1924	Year Built (Alt. Source) 1924	Est. Decade Built 1950
Total Area (square ft) 17919	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 SE Vertical Irregularity Primary		 NW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries