

La Grande Middle School

La Grande SD 1

Unio_sch02A

Building Type School	County Union	
Street 1108 4th St		
City La Grande	State OR	Zip 97850
Latitude 45.32166	Longitude 118.09722	
Tracking Code RVS in 2006	Inspection Date 8/3/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	PC1	3.2	0	-0.5	0	0	0	-1	0	1.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

La Grande Middle School

Final RVS Score

Final Type	Final Score
PC1	1.7

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

La Grande Middle School

Unio_sch02A

Enrollment 341	Year Built (Field Verified) 1976	Year Built (Alt. Source) 1976	Est. Decade Built 1970
Total Area (square ft) 50357	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other None None		Steps in Elevation View: Very Irregular Changes None None	
Falling Hazards		Poor Conditions	
None None None		None None None	
			
N Elevation View		N Elevation View	
		W Elevation View	
		SW Elevation View	

La Grande Middle School

La Grande SD 1

Unio_sch02B

Building Type School	County Union	
Street 1108 4th St		
City La Grande	State OR	Zip 97850
Latitude 45.32222	Longitude 118.09765	
Tracking Code RVS in 2006	Inspection Date 8/3/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	0	-0.4	0	0	-0.8	0	0.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

La Grande Middle School

Final RVS Score

Final Type	Final Score
URM	0.7

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

La Grande Middle School

Unio_sch02B

Enrollment 341	Year Built (Field Verified) 1976	Year Built (Alt. Source) 1976	Est. Decade Built 1920
Total Area (square ft) 50357	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
S Primary Structural Type		E Elevation View	