

Cove School

Cove SD 15

Unio_sch1A

Building Type School	County Union	
Street 803 Main St		
City Cove	State OR	Zip 97824
Latitude 45.29726	Longitude 117.80971	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	0	0	0	-1.2	0	0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Cove School

Final RVS Score

Final Type	Final Score
W2	0.1

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Enrollment 254	Year Built (Field Verified) 1935	Year Built (Alt. Source) 1935	Est. Decade Built 1960
Total Area (square ft) 34801	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: Very Irregular Changes None None	
Falling Hazards None None None		Poor Conditions None None None	

Cove School

Cove SD 15

Unio_sch1B

Building Type School	County Union	
Street 803 Main St		
City Cove	State OR	Zip 97824
Latitude 45.29756	Longitude 117.81027	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	0	0	0	0	-1.2	0	3.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Cove School

Final RVS Score

Final Type	Final Score
W2	3.6

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Cove School

Unio_sch11B

Enrollment 254	Year Built (Field Verified) 1935	Year Built (Alt. Source) 1935	Est. Decade Built 1960
Total Area (square ft) 34801	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 SE Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Cove School

Cove SD 15

Unio_sch11C

Building Type School	County Union	
Street 803 Main St		
City Cove	State OR	Zip 97824
Latitude 45.29653	Longitude 117.80858	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C2	3.6	-2	-0.5	-0.4	0	0	-1.2	0	-0.5
Secondary	W2	4.8	-3	-0.5	-0.2	0	0	-1.2	0	-0.1
Tertiary		0	0	0	0	0	0	0	0	0

Cove School

Final RVS Score

Final Type	Final Score
C2	-0.5

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Cove School

Unio_sch11C

Enrollment 254	Year Built (Field Verified) 1935	Year Built (Alt. Source) 1940	Est. Decade Built 1940
Total Area (square ft) 34801	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: T shaped Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
 W Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Cove School

Cove SD 15

Unio_sch11D

Building Type School	County Union	
Street 803 Main St		
City Cove	State OR	Zip 97824
Latitude 45.29636	Longitude 117.80877	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Cove School

Final RVS Score

Final Type	Final Score
RM1	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Enrollment 254	Year Built (Field Verified) 1935	Year Built (Alt. Source) 1935	Est. Decade Built 1980
Total Area (square ft) 34801	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: Single Change Steps in Elevation View: Single Change (Adjacent Building/Entity) None	
Falling Hazards None None None		Poor Conditions None None None	

Cove School

Cove SD 15

Unio_sch11E

Building Type School	County Union	
Street 803 Main St		
City Cove	State OR	Zip 97824
Latitude 45.29651	Longitude 117.80916	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	-3	-0.5	-0.2	0	0	-1.2	0	-0.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Cove School

Final RVS Score

Final Type	Final Score
W2	-0.1

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Cove School

Unio_sch11E

Enrollment 254	Year Built (Field Verified) 1935	Year Built (Alt. Source) 1935	Est. Decade Built 1930
Total Area (square ft) 34801	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Steps in Elevation View: Single Change (Adjacent Building/Entity) None	
Falling Hazards Unreinforced Chimneys None None		Poor Conditions None None None	
 S Elevation View		 E Elevation View	
		 NE Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Cove School

Cove SD 15

Building Type	County
School	Union
Street	
803 Main St	
City	State Zip
Cove	OR 97824
Latitude	Longitude
45.29618	117.80898
Tracking Code	Inspection Date
RVS in 2006	8/14/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W2	4.8	0	-0.5	0	1.6	0	-1.2	0	4.7
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Cove School

Final RVS Score

Final Type	Final Score
W2	4.7

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Cove School

Unio_sch11F

Enrollment 254	Year Built (Field Verified) 1935	Year Built (Alt. Source) 1935	Est. Decade Built 1990
Total Area (square ft) 34801	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 SW Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries