

Greenwood Elementary School

La Grande SD 1

Unio_sch12A

| | | |
|------------------------------|-----------------------------|--------------|
| Building Type School | County Union | |
| Street 2300 N Spruce St | | |
| City La Grande | State OR | Zip 97850 |
| Latitude 45.3335 | Longitude 118.08717 | |
| Tracking Code RVS in 2006 | Inspection Date 8/3/2006 | |



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | W2 | 4.8 | -3 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | 0.1 |
| Secondary | RM1 | 3.6 | -2 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | -0.1 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Greenwood Elementary School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| RM1 | -0.1 |

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Greenwood Elementary School

Unio_sch12A

| | | | |
|--|-------------------------------------|---|---------------------------|
| Enrollment 354 | Year Built (Field Verified) 1960 | Year Built (Alt. Source) 1960 | Est. Decade Built 1950 |
| Total Area (square ft) 34919 | Number of Stories 1 | Basement | Pounding Potential No |
| Plan Irregularities | | Vertical Irregularities | |
| Reentrant Corners: U shaped | | Steps in Elevation View: Single Change (Adjacent Building/Entity) | |
| Reentrant Corners: Other (Adjacent Build/Entity) | | None | |
| None | | None | |
| Falling Hazards | | Poor Conditions | |
| Unreinforced Chimneys | | None | |
| None | | None | |
| None | | None | |
|  | |  | |
| SW Falling Hazard | | SW Plan Irregularity Primary | |



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Greenwood Elementary School

La Grande SD 1

Unio_sch12B

| | | |
|------------------|-----------------|-------|
| Building Type | County | |
| School | Union | |
| Street | | |
| 2300 N Spruce St | | |
| City | State | Zip |
| La Grande | OR | 97850 |
| Latitude | Longitude | |
| 45.33394 | 118.08688 | |
| Tracking Code | Inspection Date | |
| RVS in 2006 | 8/3/2006 | |



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

| | Type | Basic Score | Vert Irreg | Plan Irreg | Pre-Code | Post-Bench | Soil C | Soil D | Soil E | RVS Score |
|-----------|------|-------------|------------|------------|----------|------------|--------|--------|--------|-----------|
| Primary | C2 | 3.6 | -2 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | -0.1 |
| Secondary | RM1 | 3.6 | -2 | -0.5 | 0 | 0 | 0 | -1.2 | 0 | -0.1 |
| Tertiary | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |

Greenwood Elementary School

Final RVS Score

| Final Type | Final Score |
|------------|-------------|
| C2 | -0.1 |

FEMA-154 Collapse Potential

Very High (100%)



OregonGeology

Greenwood Elementary School

Unio_sch12B

| | | | |
|---|-------------------------------------|--|---------------------------|
| Enrollment 354 | Year Built (Field Verified) 1960 | Year Built (Alt. Source) 1960 | Est. Decade Built 1960 |
| Total Area (square ft) 34919 | Number of Stories 1 | Basement | Pounding Potential No |
| Plan Irregularities Reentrant Corners:L shaped (Adjacent Build/Entity) None None | | Vertical Irregularities Steps in Elevation View: Single Change Steps in Elevation View: Single Change (Adjacent Building/Entity) None | |
| Falling Hazards None None None | | Poor Conditions None None None | |