

# Emergency Operations Center

Wallowa County

Wall\_eoc01A

Building Type	County
EOC-Public Safety Answering P	Wallowa
Street	
104 West Greenwood	
City	State Zip
Enterprise	OR 97828
Latitude	Longitude
45.42506	117.27689
Tracking Code	Inspection Date
RVS in 2006	8/12/2006



Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	0	-0.8	0	0.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

## Emergency Operations Center

### Final RVS Score

Final Type	Final Score
URM	0.2

### FEMA-154 Collapse Potential

High (>10%)

No  
Planview  
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

# Emergency Operations Center

Wall\_eoc01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1909	1909	1900
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	Yes	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
SW Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries