

Building Type	County
Fire - City	Wallowa
Street	
201 N Russell St	
City	State Zip
Joseph	OR 97846
Latitude	Longitude
45.35367	117.23557
Tracking Code	Inspection Date
RVS in 2006	8/12/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	0	0	0	0	-1	0	2.8
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Joseph Fire Dept

Final RVS Score

Final Type	Final Score
S3	2.8

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



Oregon Geology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		Steps in Elevation View: Single Change	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NW Elevation View			

