

Wallowa FD

Wall_fir04A

Wallowa FD

Building Type		County	
Fire - RFPD		Wallowa	
Street			
60000 Mt Howard Ln			
City	State	Zip	
Joseph	OR	97846	
Latitude		Longitude	
45.27873		117.20684	
Tracking Code		Inspection Date	
RVS in 2006		8/13/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	-0.5	0	0	0	-1	0	2.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Wallowa FD

Final RVS Score

Final Type

Final Score

S3

2.3

FEMA-154 Collapse Potential

Low (<1%)




OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			2000
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



SE Elevation View