

Lostine VFD

Lostine VFD

Wall_fir05A

Building Type Fire - RFPD	County Wallowa	
Street 128 Hwy 82		
City Lostine	State OR	Zip 97857
Latitude 45.48686	Longitude 117.43177	
Tracking Code RVS in 2006	Inspection Date 8/14/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	-3.5	-0.5	0	0	0	-0.6	0	0.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Lostine VFD

Final RVS Score

Final Type	Final Score
W1	0.6

FEMA-154 Collapse Potential

High (>10%)



OregonGeology

Lostine VFD

Wall_fir05A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
Reentrant Corners: L Shaped		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E	Elevation View	SE	Plan Irregularity Secondary



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries