

OSP

Wall\_pol03A

Oregon State Police

Building Type Police - State	County Wallowa	
Street 65495 Alder Slope Rd		
City Enterprise	State OR	Zip 97828
Latitude 45.41519	Longitude 117.30094	
Tracking Code New Building	Inspection Date 8/12/2006	



Seismicity Zone: Moderate

#### FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	1.6	0	-0.6	0	6.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

OSP

#### Final RVS Score

Final Type	Final Score
W1	6.2

#### FEMA-154 Collapse Potential

Low (<1%)



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			2000
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	2	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
W	Elevation View	S	Building Name
		S Other	

