

Enterprise High School

Enterprise SD 21

Wall_sch04A

Building Type	County
School	Wallowa
Street	
201 Se 4th St	
City	State Zip
Enterprise	OR 97828
Latitude	Longitude
45.42491	117.27258
Tracking Code	Inspection Date
RVS in 2006	8/12/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	3.4	-1.5	-0.5	-0.4	0	-0.4	0	0	0.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Enterprise High School

Final RVS Score

Final Type	Final Score
URM	0.6

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enterprise High School

Wall_sch04A

Enrollment 159	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built 1910
Total Area (square ft) 35293	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Steps in Elevation View: 2 to 3 Changes	
Reentrant Corners: Other		Steps in Elevation View: Single Change (Adjacent Building/Entity)	
None		None	
Falling Hazards		Poor Conditions	
Other: Heavy cornice or other overhead decoration		None	
Parapets: Unreinforced Around Entire Building		None	
None		None	
			
N Elevation View		NE Elevation View	
		N Plan Irregularity Primary	
			
E Elevation View		E Primary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enterprise High School

Enterprise SD 21

Wall_sch04B

Building Type	County
School	Wallowa
Street	
201 Se 4th St	
City	State Zip
Enterprise	OR 97828
Latitude	Longitude
45.42494	117.27195
Tracking Code	Inspection Date
RVS in 2006	8/12/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Enterprise High School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enterprise High School

Wall_sch04B

Enrollment 159	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built 1950
Total Area (square ft) 35293	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes (Adjacent Building/Entity) Steps in Elevation View: Single Change Building On Hill or Sloped Site	
Falling Hazards None None None		Poor Conditions None None None	
			
E Primary Structural Type		SW Elevation View	NW Elevation View

Enterprise High School

Enterprise SD 21

Wall_sch04C

Building Type School	County Wallowa	
Street 201 Se 4th St		
City Enterprise	State OR	Zip 97828
Latitude 45.42481	Longitude 117.27331	
Tracking Code RVS in 2006	Inspection Date 8/12/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Enterprise High School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enterprise High School

Wall_sch04C

Enrollment 159	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built 1950
Total Area (square ft) 35293	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped None None		Vertical Irregularities Building On Hill or Sloped Site None None	
Falling Hazards None None None		Poor Conditions None None None	
 E Elevation View			



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enterprise High School

Enterprise SD 21

Wall_sch04D

Building Type School	County Wallowa	
Street 201 Se 4th St		
City Enterprise	State OR	Zip 97828
Latitude 45.42496	Longitude 117.27166	
Tracking Code RVS in 2006	Inspection Date 8/12/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Enterprise High School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enterprise High School

Wall_sch04D

Enrollment 159	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built 1970
Total Area (square ft) 35293	Number of Stories 1	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners:Other (Adjacent Build/Entity) Reentrant Corners: L Shaped None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) Building On Hill or Sloped Site None	
Falling Hazards None None None		Poor Conditions None None None	
			
SE Elevation View		SW Plan Irregularity Secondary	
			
		W Vertical Irregularity Secondary	

Enterprise High School

Enterprise SD 21

Wall_sch04E

Building Type School	County Wallowa	
Street 201 Se 4th St		
City Enterprise	State OR	Zip 97828
Latitude 45.42433	Longitude 117.27206	
Tracking Code RVS in 2006	Inspection Date 8/12/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	-0.8	0	0	0.3
Secondary	W2	4.8	-3	-0.5	0	0	-0.8	0	0	0.5
Tertiary		0	0	0	0	0	0	0	0	0

Enterprise High School

Final RVS Score

Final Type	Final Score
RM1	0.3

FEMA-154 Collapse Potential

High (>10%)

No
Planview
Available



Oregon Geology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enterprise High School

Wall_sch04E

Enrollment 159	Year Built (Field Verified) 1917	Year Built (Alt. Source) 1917	Est. Decade Built 1970
Total Area (square ft) 35293	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: L Shaped Reentrant Corners: Other None		Vertical Irregularities Steps in Elevation View: Single Change (Adjacent Building/Entity) None None	
Falling Hazards None None None		Poor Conditions None None None	
			
E Elevation View 200 addition		W Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries