

Building Type	County	
Community_College	Hood River	
Street		
616 Industrial St		
City	State	Zip
Hood River	OR	97031
Latitude	Longitude	
45.59089	121.18995	
Tracking Code	Inspection Date	
Miller 2004-05	8/8/2005	

Seismicity Zone: Moderate

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	C1	3.2	-2	-0.5	-1	0	0	0	0	-0.3
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

The Dalles - Bldg 2 - Administration

## Final RVS Score

Final Type

Final Score

C1

-0.3

## FEMA-154 Collapse Potential

Very High (100%)

# No Planview Available



# The Dalles - Bldg 2 - Administration

Wasc\_coc01A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
	1929	1929	1920
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
46420	4	Yes	No

Plan Irregularities	Vertical Irregularities
Yes: Unknown	Yes: Unknown

Falling Hazards	Poor Conditions
Parapets: General	
Other: Light Cladding	
None	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment  
Oregon Department of Geology and Mineral Industries