

Building Type	County
EOC-Public Safety Answering P	Wasco
Street	
203A E 4th St	
City	State Zip
The Dalles	OR 97058
Latitude	Longitude
45.60062	121.18385
Tracking Code	Inspection Date
RVS in 2006	8/23/2006



Seismicity Zone: High

## FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	URM	1.8	0	0	-0.2	0	-0.4	0	0	1.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Wasco County Communications 911

## Final RVS Score

Final Type	Final Score
URM	1.2

## FEMA-154 Collapse Potential

Moderate (&gt;1%)

No  
Planview  
Available



Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1910
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Reentrant Corners: Other		Building On Hill or Sloped Site	
None		None	
None		None	
Falling Hazards		Poor Conditions	
Other: General		None	
Parapets: Unreinforced Around Entire Building		None	
Unreinforced Chimneys		None	
			
S	Falling Hazard	S	Building Quality raked jts
			
W	Elevation View	N	Falling Hazard
			
N	Primary Structural Type	N	Falling Hazard
			
E	Seismic Upgrade only on e side	E	Plan Irregularity Primary

