

Mosier Fire Depart - City Hall

Wasc_fir04A

City of Mosier

Building Type Fire - City	County Wasco	
Street 208 Washington St		
City Mosier	State OR	Zip 97040
Latitude 45.68286	Longitude 121.3984	
Tracking Code RVS in 2006	Inspection Date 8/24/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	-0.5	0	0	0	0	0	3.3
Secondary	W1	5.2	0	-0.5	0	0	0	0	0	4.7
Tertiary		0	0	0	0	0	0	0	0	0

Mosier Fire Depart - City Hall

Final RVS Score

Final Type	Final Score
S3	3.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mosier Fire Depart - City Hall

Wasc_fir04A

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1960
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		Building On Hill or Sloped Site	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
S Building Name		SE Elevation View	
		NE Elevation View	



OregonGeology


Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mosier Fire Depart - City Hall

Wasc_fir04B

City of Mosier

Building Type Fire - City	County Wasco	
Street 208 Washington St		
City Mosier	State OR	Zip 97040
Latitude 45.68294	Longitude 121.39843	
Tracking Code RVS in 2006	Inspection Date 8/24/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	W1	5.2	0	0	0	0	0	0	0	5.2
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

Mosier Fire Depart - City Hall

Final RVS Score

Final Type	Final Score
W1	5.2

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mosier Fire Depart - City Hall

Wasc_fir04B

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1930
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
E Building Name		E Other	
			
		NW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Mosier Fire Depart - City Hall

Wasc_fir04C

City of Mosier

Building Type Fire - City	County Wasco	
Street 208 Washington St		
City Mosier	State OR	Zip 97040
Latitude 45.68303	Longitude 121.39843	
Tracking Code RVS in 2006	Inspection Date 8/24/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	0	0	0	0	0	0	3.8
Secondary	W1	5.2	0	0	0	1.6	0	0	0	6.8
Tertiary		0	0	0	0	0	0	0	0	0

Mosier Fire Depart - City Hall

Final RVS Score

Final Type	Final Score
S3	3.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Mosier Fire Depart - City Hall

Wasc_fir04C

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1990
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
None		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Elevation View		SW Elevation View	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries