

Mosier RFD

City of Mosier

Wasc_fir05A

Building Type	County
Fire - City	Wasco
Street	
1250 State Rd	
City	State Zip
Mosier	OR 97040
Latitude	Longitude
45.67935	121.38446
Tracking Code	Inspection Date
RVS in 2006	8/24/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	-0.5	0	0	-0.6	0	0	2.7
Secondary	W1	5.2	0	-0.5	0	0	-0.2	0	0	4.5
Tertiary		0	0	0	0	0	0	0	0	0

Mosier RFD

Final RVS Score

Final Type	Final Score
S3	2.7

FEMA-154 Collapse Potential

Low (<1%)

No
Planview
Available



OregonGeology

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1970
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No
Plan Irregularities		Vertical Irregularities	
Torsion: Eccentric Stiffness		None	
None		None	
None		None	
Falling Hazards		Poor Conditions	
None		None	
None		None	
None		None	
			
NE Elevation View		SE Elevation View	
			
NW Elevation View		NW Elevation View county rd maint beyond	

