

Tygh Valley FD

Tygh Valley FD

Wasc_fir07A

Building Type		County	
Fire - RFPD		Wasco	
Street			
Corner of Oakgrove and Tygh Valley Rd			
City	State	Zip	
Tygh Valley	OR	97063	
Latitude		Longitude	
45.24731		121.17583	
Tracking Code		Inspection Date	
RVS in 2006		8/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	-0.5	0	0	0	-1	0	2.3
Secondary	W1	5.2	0	-0.5	0	1.6	0	-0.6	0	5.7
Tertiary		0	0	0	0	0	0	0	0	0

Tygh Valley FD

Final RVS Score

Final Type

Final Score

S3

2.3

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
			1980
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
	1	No	No

Plan Irregularities	Vertical Irregularities
Torsion: Eccentric Stiffness	None
None	None
None	None

Falling Hazards	Poor Conditions
None	None
None	None
None	None



NE Elevation View



Tygh Valley FD

Wasc_fir07B

Tygh Valley FD

Building Type		County	
Fire - RFPD		Wasco	
Street			
Corner of Oakgrove and Tygh Valley Rd			
City	State	Zip	
Tygh Valley	OR	97063	
Latitude		Longitude	
45.24719		121.17598	
Tracking Code		Inspection Date	
RVS in 2006		8/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	S3	3.8	0	0	0	0	0	-1	0	2.8
Secondary	W1	5.2	0	0	0	1.6	0	-0.6	0	6.2
Tertiary		0	0	0	0	0	0	0	0	0

Tygh Valley FD

Final RVS Score

Final Type

Final Score

S3

2.8

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

Enrollment	Year Built (Field Verified)	Year Built (Alt. Source)	Est. Decade Built
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text" value="1990"/>
Total Area (square ft)	Number of Stories	Basement	Pounding Potential
<input type="text"/>	<input type="text" value="1"/>	<input type="text" value="No"/>	<input type="text" value="No"/>

Plan Irregularities	Vertical Irregularities
<input type="text" value="None"/>	<input type="text" value="None"/>
<input type="text" value="None"/>	<input type="text" value="None"/>
<input type="text" value="None"/>	<input type="text" value="None"/>

Falling Hazards	Poor Conditions
<input type="text" value="None"/>	<input type="text" value="None"/>
<input type="text" value="None"/>	<input type="text" value="None"/>
<input type="text" value="None"/>	<input type="text" value="None"/>



SW Elevation View

