

South Wasco County High School

South Wasco County SD 1

Wasc_sch03A

Building Type	County
School	Wasco
Street	
699 4th St	
City	State Zip
Maupin	OR 97037
Latitude	Longitude
45.17741	121.08132
Tracking Code	Inspection Date
RVS in 2006	8/25/2006



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	-2	-0.5	0	0	0	0	0	1.1
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

South Wasco County High School

Final RVS Score

Final Type	Final Score
RM1	1.1

FEMA-154 Collapse Potential

Moderate (>1%)



OregonGeology

South Wasco County High School

Wasc_sch03A

Enrollment 141	Year Built (Field Verified) 1955	Year Built (Alt. Source) 1955	Est. Decade Built 1950
Total Area (square ft) 42724	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities Reentrant Corners: Other None None		Vertical Irregularities Steps in Elevation View: 2 to 3 Changes Building On Hill or Sloped Site None	
Falling Hazards Other: Ornamental Hazard Over Exit None None		Poor Conditions None None None	
			
E Building Name	E Falling Hazard	S Vertical Irregularity Secondary	
			
SW Vertical Irregularity Primary	SW Primary Structural Type	W General Site	
			
NW General Site	N Elevation View	N Primary Structural Type	



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

South Wasco County High School

South Wasco County SD 1

Wasc_sch03B

Building Type	County	
School	Wasco	
Street		
699 4th St		
City	State	Zip
Maupin	OR	97037
Latitude	Longitude	
45.17741	121.08218	
Tracking Code	Inspection Date	
RVS in 2006	8/25/2006	



Seismicity Zone: Moderate

FEMA 154 Rapid Visual Screening Score Card

	Type	Basic Score	Vert Irreg	Plan Irreg	Pre-Code	Post-Bench	Soil C	Soil D	Soil E	RVS Score
Primary	RM1	3.6	0	0	0	0	0	0	0	3.6
Secondary		0	0	0	0	0	0	0	0	0
Tertiary		0	0	0	0	0	0	0	0	0

South Wasco County High School

Final RVS Score

Final Type	Final Score
RM1	3.6

FEMA-154 Collapse Potential

Low (<1%)



OregonGeology

Rapid Visual Screening - Senate Bill #2 - Seismic Needs Assessment
Oregon Department of Geology and Mineral Industries

South Wasco County High School

Wasc_sch03B

Enrollment 141	Year Built (Field Verified) 1955	Year Built (Alt. Source) 1955	Est. Decade Built 1970
Total Area (square ft) 42724	Number of Stories 2	Basement	Pounding Potential No
Plan Irregularities None None None		Vertical Irregularities None None None	
Falling Hazards None None None		Poor Conditions None None None	
 NW Elevation View			